

SCHEDULE NO. LA-4
Los Angeles County Division
PRIVATE FIRE SERVICE

SPECIAL CONDITIONS - Continued

- 6. No structure shall be built over the private fire service facilities and the customer shall maintain and safeguard the area occupied by the private fire service facilities from traffic and other hazardous conditions. The customer will be responsible for any damage to the private fire service facilities whether resulting from the use or operation of appliances and facilities on customer's premises or otherwise. (T)
- 7. Subject to the approval of the utility, any change in the location or construction of the private fire service facilities as may be requested by public authority or the customer will be made by the utility following payment to the utility of the entire cost of such change. (T)
- 8. The customer's installation must be such as to separate effectively the private fire service facilities from that of the customer's regular domestic water service. Any unauthorized use of water from the private fire service facilities will be charged for at the applicable tariff rates and may be grounds for the utility's discontinuing private fire service without liability to the utility. (T)
- 9. There shall be no cross connection between the systems supplied by water through the utility's private fire service facilities and any other source of supply without the specific approval of the utility. The specific approval, if given, will at least require at the customer's expense, a special double check valve installation or other backflow prevention device acceptable to the utility. Any unauthorized cross connection may be grounds for immediately discontinuing private fire service without liability to the utility. (T)
- 10. The utility will supply only such water at such pressure as may be available from time to time as a result of its operation of the system. The customer shall indemnify the utility and save it harmless against any and all claims arising out of service under this schedule and shall further agree to make no claims against the utility for any loss or damage resulting from service under this schedule. Section 774 of the Public Utilities Code limits the liability of the utility resulting from a claim regarding adequacy of pressure or supply for fire protection service. (T)
- 11. The customer shall be responsible for the periodic testing of any backflow prevention devices as required by public authority or the utility. Any repair or replacement of such devices or of any other facilities installed to provide private fire service shall be done at the customer's expense. Any refusal to comply with the above requirements may be grounds for the utility's discontinuing private fire service without liability to the utility. (T)

(To be inserted by utility)
Advice Letter No. 223
Decision No. _____

Issued by
R. E. Heytens
NAME
Vice President
TITLE

(To be inserted by Cal. P.U.C.)
Date Filed Jan 29, 1986
Effective Feb 28, 1986
Resolution No. _____