

SCHEDULE NO. FO-4
Fontana Water Company
PRIVATE FIRE SERVICE

APPLICABILITY

Applicable to water service furnished to private fire systems and to private fire hydrants.

TERRITORY

Portions of Fontana, Rancho Cucamonga, Rialto and vicinity, San Bernardino County.

RATE

Per Service
Per Month

For each inch of diameter of service connection.....\$10.26 (I)

SPECIAL CONDITIONS

1. The customer will pay, without refund, the entire cost of the private fire service facilities.
2. The private fire service facilities shall be installed by the utility or under the utility's direction and shall be the sole property and subject to the control of the utility, with the right to alter, repair, replace and the right to remove upon discontinuance of service.
3. The minimum diameter for the private fire service connection will be 4-inches. The maximum diameter shall not be larger than the diameter of the water main to which the private fire service facilities are attached unless said main is circulating, in which case with the approval of the utility the maximum diameter may be larger by not more than 2-inches than the diameter of said circulating main.
4. If a water main of adequate size is not available adjacent to the premises to be served, then a new main from the nearest existing main of adequate size will be installed by the utility at the cost of the customer. Such cost shall not be subject to refund.
5. The private fire service facilities will include a detector check valve or other similar device acceptable to the utility which will indicate the use of water. The facilities may be located within the customer's premises or within public right of way adjacent thereto. Where located within the premises, the utility and its duly authorized agents shall have the right of ingress to and egress from the premises for all purposes related to said facilities. In the event the installation is solely a private fire hydrant facility, the requirement for a detector check valve or other similar device may be waived.

(continued)